

LOW PRESSURE CUT-OFF CONTROLLER TEST REPORT

Premises Address: _____ Company Name: _____
 Contact Name: _____ Contact Phone No: _____ Type
 of Controller: Fire Pump _____ Domestic Booster Pump _____ Pressure Sustaining Valve _____ Manuf:
 Model No: _____ Serial No: _____ Type of Inspection: Initial
 Annual _____ Date of Inspection: _____

YES	NO	
_____	_____	Found the sensing line seal intact
_____	_____	Found the normal power light (green) on

MANUAL START

_____	_____	Low suction light (red) comes on when suction pressure reaches 10 psig
_____	_____	The alarm sounds after a minimum 30 second delay
_____	_____	The pump shuts off immediately after the low suction pressure alarm sounds
_____	_____	The pump has automatic restart when the sensing line is recharged

AUTOMATIC START

_____	_____	Low suction light (red) comes on when suction pressure reaches 10 psig
_____	_____	The alarm sounds after a minimum 30 second delay
_____	_____	The pump shuts off immediately after the low-suction pressure alarm sounds
_____	_____	The pump has automatic restart when the sensing line is recharged

RESET PUMP

_____	_____	Opened outlet valve at pump discharge
_____	_____	Pump restarted in manual start mode
_____	_____	Pump restarted in automatic start mode
_____	_____	Resealed sensing line valve in open position

I certify that the low pressure cut-off controller test as described above was performed by me on the date indicated and the findings were as indicated:

INSPECTOR:

Signature _____ Printed Name: _____

Cert. Tester No: _____ Date: _____

I certify that the inspection was performed on the date indicated and that the following statement is true. The low-suction pressure cut-off controller has been in use during the interval between inspections and during that period has not been bypassed or otherwise made ineffective.

Company Representative:

Name (Please Print) _____ Date: _____

Signature _____ Title: _____